





MODEL # FWP-PC-4623-2



SECTION



SIDE



PLAN

OPTIONAL ANTI-FLOAT BASE. NOTE: SIZING IS SITE SPECIFIC AND REQUIRES ENGINEERING DESIGN AND APPROVAL

DESIGN DATA

FRASER WAY PRECAST MODEL # FWP-ST-4623-1
 WEIGHT: LID 3300 LBS
 BOTTOM 8730 LBS

WORKING VOLUMES:
 1ST CHAMBER= 4623 L 1000 I.G.

CONCRETE TANK STRUCTURAL REINFORCING
 (STRUCTURAL REINFORCING DESIGN BY OTHERS)

BASE REBAR
 10M @ 12" (305mm) O.C. ON BOTTOM w/12" (305mm) BENT OVERLAP SIDES, 10M UNDER DIVIDE (TOTAL 2)
 4x4 / 10 GA. WWM REINFORCING w/12" (305mm) WRAP EACH END

SIDEWALL REBAR
 2-10M (TOTAL 2) REBAR BENT COLD AT CORNERS WELDED IN LOOP
 4x4 / 10 GA. WWM REINFORCING w/12" (305mm) WRAP EACH END

GASKET: CONCEAL CS-120

CONCRETE STRENGTH: 25 MPa MINIMUM
 (USE IN NON-SULPHATE SOILS ONLY)

ALL DIMENSIONS SHOWN IN INCHES

FRASERWAY PRECAST LTD

22765 FRASER HIGHWAY
 LANGLEY, BC V3A 4R6
 TEL: 604-534-2911 FAX: 604-533-3238
 EMAIL: INFO@FRASERWAYPRECAST.COM
 WWW.FRASERWAYPRECAST.COM

1000 gal - 4623 L - 1 COMPARTMENT, 1 PIECE PUMP CHAMBER PLAN, SIDE AND SECTION

DRAWN: EJP	SHEET: 1 / 1	FILE NO. 600	REV:
DATE: JUNE 26, 2010	REV DATE: REV TYPE:		