




# MODEL # FWP-PC-909-1



**SECTION**



**SIDE**



**PLAN**

## DESIGN DATA

FRASER WAY PRECAST MODEL # FWP-PC-909-1  
WEIGHT: 2500 LBS

WORKING VOLUMES:  
1ST CHAMBER= 909 L 200 I.G.

CONCRETE TANK STRUCTURAL REINFORCING  
(STRUCTURAL REINFORCING DESIGN BY OTHERS)

**BASE REBAR**  
10M @ 12" (305mm) O.C. ON BOTTOM w/12" (305mm) BENT OVERLAP SIDES,  
2PCS 10M UNDER DIVIDE  
4x4 / 10 GA. WWM REINFORCING w/12" (305mm)  
WRAP EACH END

**SIDEWALL REBAR**  
2-10M (TOTAL 2) REBAR BENT COLD AT CORNERS  
WELDED IN LOOP  
4x4 / 10 GA. WWM REINFORCING w/12" (305mm)  
WRAP EACH END

GASKET: CONCEAL CS-120

CONCRETE STRENGTH: 25 MPa MINIMUM  
(USE IN NON-SULPHATE SOILS ONLY)

**ALL DIMENSIONS SHOWN IN INCHES**

**FRASERWAY PRECAST LTD**

22765 FRASER HIGHWAY  
LANGLEY, BC V3A 4R6  
TEL: 604-534-2911 FAX: 604-533-3238  
EMAIL: INFO@FRASERWAYPRECAST.COM  
WWW.FRASERWAYPRECAST.COM

**200 gal - 909 L - 1 COMPARTMENT, 1 PIECE  
PUMP CHAMBER  
PLAN, SIDE AND SECTION**

DRAWN: EJP	SHEET: 1 / 1	FILE NO. 350	REV:
DATE: JUNE 26, 2010	REV DATE: REV TYPE:		